

**36-132. Gas stove connections; approval of state fire marshal.** Within any place of assembly flexible metal gas connectors may be used in connection with natural gas-fired movable cooking equipment, if such flexible metal gas connectors are of a design and construction approved by the state fire marshal for such purposes as provided by K.S.A. 36-133.

**History:** L. 1976, ch. 203, § 2; July 1.